

**MCERTS Bulletin 15  
Exceeding MCERTS concessions**

MCERTS site performance requirements are for total daily volume to be measured to a target total uncertainty of  $\pm 8\%$  at a confidence level of 95%.

MCERTS Inspectors are reminded that this target may still be met even if specific MCERTS concessions are exceeded.

The MCERTS Inspector will exercise professional judgement in determining the effect of any parameter which exceeds any concession allowable under MCERTS.